

QO™ Plug-On Neutral Load Center and Interiors (PRB-236759) Frequently Asked Questions

▲ Indoor Load Center Inspection—Installed


1	Open Load Center cover door to expose the directory label. The door may open to the left or right according to its orientation.
2	Determine if the product is a Square D Load Center by confirming the brand located under the UL mark.
3	Determine if the panel is a QO Load Center by validating the first 3 digits of the part (number?) beginning with "QOCxxxx" .
4	Check the date code on the label to determine if it is within scope.

Validate that the date code is within scope of the safety notice. Date code is translated as: YYWWDS. YY=Year, WW=Week; D=Day of the week; S=Shift.

Example Shown:

- Date Code = 221111
- Year 22, Week 11, Day 1, Shift 1
- Date = March 7, 2021 Shift 1

If date code is between December 1st 2019 (194921) and March 12th 2022 (221163), then the product is within scope of the safety notice and may be affected.



19) How can the date code be found on an affected installed load center – Outdoor (Consumer / Unqualified Personnel)